

# **AMBERWOODS**

## **ORMOND BEACH, FLORIDA**

### **CALCULATION MANUAL**

**PREPARED FOR:**  
U.S. CAPITAL ALLIANCE, LLC  
880 AIRPORT ROAD  
SUITE 113  
ORMOND BEACH, FL 32174

**DATE:**  
**SEPTEMBER 19, 2022**  
**REVISED JUNE 7, 2023**

Kimberly A. Buck, State of Florida, Professional Engineer,  
License No. 38565; This item has been electronically  
signed and sealed by Kimberly A. Buck on the date  
indicated here using a SHA authentication code. Printed  
copies of this document are not considered signed and  
sealed and the SHA authentication code must be verified  
on any electronic copies.

Kimberly A. Buck,  
State of Florida,  
Professional Engineer,  
License No. 38565  
2023.06.09  
09:13:30  
-04'00'

**TABLE OF CONTENTS**

I. PROJECT NARRATIVE.....	3
APPENDIX A – POTABLE HYDRAULIC CALCULATIONS.....	4
1. <i>DOMESTIC FLOW DEMAND</i> .....	4
2. <i>WATERCAD</i> .....	4
A. <i>NODAL DIAGRAM</i> .....	4
B. <i>PHF + NFF</i> .....	4
APPENDIX B – LIFT STATION CALCULATIONS .....	5
1. <i>PUMP SIZING</i> .....	5
2. <i>WET WELL DESIGN</i> .....	5
3. <i>BUOYANCE CHECK</i> .....	5
4. <i>PUMP DATA SHEETS</i> .....	5

# I. Project Narrative

---

Developer:	U.S. CAPITAL ALLIANCE, LLC
Project Name:	<b>Amberwoods</b>
Location:	SEC of Airport Rd. and Hunters Ridge Blvd.
Legal Description:	See Boundary Survey
Existing Use:	Wooded
Proposed Use:	Single-family residential

---

## Project Description

The Amberwoods Subdivision will be an 40-lot single family subdivision on 24.26 acres. The project includes the construction of a surface water management system, utility infrastructure, and roadway improvements. The project is located within the limits of the City of Ormond Beach, Florida.

## Water Distribution System

The water distribution system has been designed to provide the demand flows needed for each lot in addition to the required fire flow. Potable water demands for the project have been calculated based on the anticipated development program and Equivalent Residential Connection (ERC) factors. The required fire flow of 1,000 gpm has been determined based on the Florida Fire Prevention Code and City requirements.

The potable water distribution system has been designed using WaterCAD v8i to complete a hydraulic model of the system and evaluate design pressures and velocities. The Peak Hourly Flow (PHF) was modeled with the needed fire flow. For model simplicity, the demand for PHF has been divided among modeled nodes for each scenario.

The WaterCAD model showed that all three hydrants can achieve the required 1,000 gpm at 20 PSI during peak hour demands. The minimum residual pressure during the fire flow events was 42 PSI with a maximum velocity of 6.6 fps.

## Wastewater Collection System

The wastewater collection system has been designed to collect the wastewater flows generated across the development via one proposed Lift Station. The lift station will discharge to the existing force main in Airport Rd. Right-of-Way.

Wastewater generation rates were calculated based on the anticipated development program and Equivalent Residential Unit (ERU) factors. Peak Design Flows (PDF) utilizing industry accepted peaking factors were used to size the gravity mains across the development and determine the design pumping rates for the lift station.

The lift station is designed to operate at 80 gpm with a TDH of 95'. The selected pump is a Sulzer / ABS Piranha grinder pump. In addition to operating at the desired operating point, the pump can handle a pressure range from 18' to 161' TDH. Making this pump ideal for the varying flow condition expected as the area continues to buildout.

## APPENDIX A – POTABLE HYDRAULIC CALCULATIONS

1. Domestic Flow Demand
2. WaterCAD
  - a. Nodal Diagram
  - b. PHF + NFF

**Amberwoods Subdivision**

**Domestic Flow Demand**

Building type	Units	ERC FACTOR	Total ERC	ADF (GPD)	TOTAL ADF (GPM)	ADF / Home (GPM)	TOTAL MDF (GPM)	MDF / Home (GPM)	TOTAL PHF (GPM)	PHF / Home (GPM)
Single Family	40.00	1.00	40.00	12000	8.33	0.21	16.67	0.42	33.33	0.83
<b>Total</b>			40.00	12,000	8.33		16.67		33.33	

**ERC Factors:**

Single-Family Home

1 per Home

1 ERC

300 GPD

MDF Factor

2


PHF Factor

4

INFORMATION		POTABLE WATER							
PHASE	CLUSTER	USE	ACRES	DENSITY	UNIT	GPD/unit	GPM x1.5	NODE	
Existing	Ommond	Residential	368.6	110	UNITS	27.22			
	Ommond	Light Industrial	40000		SF	0.2	8.3	26	
	Ommond	Residential	-	100	UNITS	300	31.3	28	
	1A	A	Ashford Lakes	87.71	77	UNITS	300	24.1	23
	1A	B	Huntington	24.03	72	UNITS	300	21.9	25
	1A	C	Huntington	103.74	183	UNITS	300	57.2	24
	1A	D	Huntington	91.03	77	UNITS	300	24.1	29
	1A	E	Donfield Estates	18.39	14	UNITS	300	4.4	22
	1B	A	Light Industrial	15.9	175072	SF	0.2	36.5	25
	1B	B	School	48	1,200	STUDENTS	30	37.5	25
	1B	C	Low Density Res	54.87	208	UNITS	300	64.4	17
	1B	D	Medium Density Res	23.15	175	UNITS	300	54.7	14
	1B	E	High Density Res	20.17	78	UNITS	300	23.8	18
	1B	F	Retail/Office/Service	27.53	213883	SF	0.2	44.6	19, 13
	1B	G	Coloading	21.3	99	UNITS	300	30.9	20
	1B	H	N/A - Recreation/Preservation				N/A	Recreation/Preservation	
	1B	I	Retail/Office/Service	5.47	34007	SF	0.2	7.1	12
	1B	J	N/A - Recreation/Preservation				N/A	Recreation/Preservation	
	1B	K	N/A - Recreation/Preservation				N/A	Recreation/Preservation	
	1B	L	Retail/Office/Service	2.91	20352	SF	0.2	4.2	19
	1B	M	Low Density Res	3.52	14	UNITS	300	4.4	20
	1B	N	Light Industrial	6.15	67716	SF	0.2	14.1	24
	1B	O	N/A - Recreation/Preservation				N/A	Recreation/Preservation	
	1B	P	Office	7.88	50908	SF	0.2	10.6	19
	1B	Q	Recreation	42.79		N/A	4.4		28
	2A	A	Low Density Res	18.34	114	UNITS	300	35.6	1
	2A	B	Medium Density Res	31.73	200	UNITS	300	62.5	1
	2A	C	N/A - Recreation/Preservation				N/A	Recreation/Preservation	
	2B	C	Low Density Res	29.58	120	UNITS	300	37.5	6
	2B	E	Low Density Res	36.44	150	UNITS	300	46.9	10
	2B	F	Low Density Res	28.04	160	UNITS	300	50.0	12, 11
	2B	G	N/A - Recreation/Preservation				N/A	Recreation/Preservation	
	3	A	Low Density Res	65.4	111	UNITS	300	38.8	30
	3	B	Medium Density Res	17.87	90	UNITS	300	28.1	5
	3	C	Medium Density Res	14.76	90	UNITS	300	28.1	5
	3	D	Medium Density Res	21.73	180	UNITS	300	58.3	8
	3	E	Medium Density Res	7.11	45	UNITS	300	14.1	7
	3	F	Medium Density Res	13.44	45	UNITS	300	14.1	9

\* Information at these locations is limited. Connection to "Briargate" through Line 15 was requested to be added to the model in meeting 03/01/2017. Connection to Breakaway at Node 33 is believed to be existing, but no As-built information has been anticipated. The connection of Lines 17 & 41 at Node 22 are unable to be verified with As-built documents. Should these lines not be existing as anticipated, connections at these locations should be made.  
 \*\* Ashford Lakes has been modeled with a connection across the FPL easement. The node at the connection point with the water line in the easement has been incorporated and shown with Node 24.

**Total Potable Water Flow of Phases 1A,1B,2A,2B & 3: 839,008 GPD**



ALANN ENGINEERING  
 CONSULTING ENGINEERS  
 LICENSE NO. 185478  
 29 GRAND BEACH, FL 32174  
 TEL: (386) 923-9490  
 FAX: (386) 973-9260

HUNTER'S RIDGE MASTER UTILITY PLAN  
 FLAGLER COUNTY, FL  
 FIGURE 4: POTABLE WATER MODEL



NO.	DATE	PER UPDATED MODEL	BY
1	10/17/17		

DATE	FILE	DESIGNER	SCALE
02-06-2017	1812-1	MBT	1"=600'


SHEET  
**WATER**

TABLE 3: Scenario 1: Full Build - No Fire Flow (FF)

Node	Demand (GPM)	Pressure (psi)	Line	Velocity (ft/s)
1	98.0	48.5	1	0.1
2	0.0	48.5	2	0.1
3	0.0	48.5	3	0.2
4	0.0	48.5	4	0.2
5	56.0	48.4	5	0.1
6	38.0	48.5	6	0.2
7	14.0	48.5	7	0.1
8	56.0	48.5	8	0.2
9	14.0	48.5	9	0.2
10	47.0	48.5	10	0.1
11	25.0	49.2	11	0.6
12	32.0	49.3	12	0.4
13	22.0	48.2	13	0.4
14	55.0	47.3	14	0.9
15	0.0	47.3	15	0.6
16	0.0	48.1	16	0.2
17	64.0	48.9	16	0.2
18	28.0	49.4	17	0.4
19	34.0	48.6	18	0.6
20	35.0	49.6	19	0.7
21	0.1	49.7	20	0.1
22	36.4	49.6	21	0
23	24.0	49.2	22	0.5
24	71.0	49.1	23	0.8
25	96.0	49.5	24	0.4
26	4.0	49.6	25	0.3
27	18.8	51.8	26	0.5
28	40.0	49.3	27	0.5
29	24.0	49.1	28	0.3
30	37.0	48.4	29	0.1
31	0.0	51	30	0.5
32	11.7	49.4	31	0.9
33	49.2	49.7	32	0.4
34	1.2	51.2	33	0
35	0.0	49.5	33	0.2
			42	0.1
			44	0.1
			38	0.2
			39	0.2
			33	0.3
			34	0.3
			40	0.4
			40	0.5
			35	0.8
			37	0.8
			41	0.9
			36	1
			41	1
			41	1
			43	1
			41	1.1
			43	1.1
			43	1.4
			43	1.4
			43	1.4



# Entire Model





## PHF + NFF

### Reservoir Table - Time: 0.00 hours

Label	Elevation (ft)	Flow (Out net) (gpm)	Hydraulic Grade (ft)	Notes
R-1	139.77	33.20	139.77	HGL = 48.6 PSI + 27.5' elevation = 112.27' + 27.5' = 139.77'

**PHF + NFF**

**Junction Table - Time: 0.00 hours**

Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
J-1	27.25	9.96	139.75	49
J-2	27.50	15.77	139.75	49
J-3	28.40	7.47	139.75	48

**PHF + NFF**  
**Pipe Table - Time: 0.00 hours**

Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Has Check Valve?	Flow (gpm)	Velocity (ft/s)
P-1	250	R-1	H-1	8.0	PVC	130.0	True	33.20	0.21
P-2	264	H-1	J-1	8.0	PVC	130.0	False	33.20	0.21
P-4	70	J-1	H-2	8.0	PVC	130.0	False	7.47	0.05
P-5	257	H-2	J-3	8.0	PVC	130.0	False	7.47	0.05
P-3	335	J-1	H-3	8.0	PVC	130.0	False	15.77	0.10
P-6	105	H-3	J-2	8.0	PVC	130.0	False	15.77	0.10

## PHF + NFF

**Fire Flow Results Table - Time: 0.00 hours**

Label	Satisfies Fire Flow Constraints?	Fire Flow (Needed) (gpm)	Fire Flow (Available) (gpm)	Pressure (Residual Lower Limit) (psi)	Pressure (Calculated Residual) (psi)	Pressure (Calculated System Lower Limit) (psi)	Junction w/ Minimum Pressure (System)	Velocity of Maximum Pipe (ft/s)
J-1	(N/A)	0.00	(N/A)	0	(N/A)	(N/A)	(N/A)	(N/A)
J-2	(N/A)	0.00	(N/A)	0	(N/A)	(N/A)	(N/A)	(N/A)
J-3	(N/A)	0.00	(N/A)	0	(N/A)	(N/A)	(N/A)	(N/A)
H-1	True	1,000.00	1,001.00	20	47	46	J-3	6.60
H-2	True	1,000.00	1,001.00	20	44	43	J-3	6.60
H-3	True	1,000.00	1,001.00	20	42	42	J-2	6.60


## APPENDIX B – LIFT STATION CALCULATIONS

1. Pump Sizing
2. Wet Well Design
3. Buoyance Check
4. Pump Data Sheets

INFORMATION				WASTEWATER				
PHASE	USE	ACRES	DENSITY	UNIT	GPD/Unit	GPD	GPM	LIFTSTATION
Existing	Residential	368.6	410	UNITS	280	114800	NA	Existing
Ormond	Ormond Light Industrial	-	40000	SF	0.15	6900	17	20
Ormond	Ormond Residential	-	100	UNITS	280	28000	78	20
1A	A Ashford Lakes	87.71	77	UNITS	280	21560	60	3->2
1A	B Huntington	24.03	70	UNITS	280	19600	54	4->2
1A	C Huntington	103.74	183	UNITS	280	51240	142	2
1A	D Huntington	81.03	77	UNITS	280	21560	60	4->2
1A	E Deerfield Estates	18.39	14	UNITS	280	3920	11	Existing
1B	A Light Industrial	15.9	175072	SF	0.15	26261	73	20
1B	B School	48	1,200	STUDENTS	24	28800	80	5
1B	C Low Density Res	54.87	206	UNITS	280	57680	169	13
1B	D Medium Density Res	23.15	175	UNITS	280	49000	136	14
1B	E Iris	20.7	76	UNITS	280	21280	59	5
1B	F Retail/Office/Service	27.53	213983	SF	0.15	32097	89	14
1B	G Caledine	21.3	89	UNITS	280	27720	77	6
1B	H N/A - Recreation/Preservation				N/A	N/A	N/A	Recreation/Preservation
1B	I Retail/Office/Service	5.47	34007	SF	0.15	5101	14	7
1B	J N/A - Recreation/Preservation				N/A	N/A	N/A	Recreation/Preservation
1B	K N/A - Recreation/Preservation				N/A	N/A	N/A	Recreation/Preservation
1B	L Retail/Office/Service	2.91	20352	SF	0.15	3053	8	5
1B	M Low Density Res	3.52	14	UNITS	280	3920	11	6
1B	N Light Industrial	6.15	67716	SF	0.15	10157	28	6
1B	O N/A - Recreation/Preservation				N/A	N/A	N/A	Recreation/Preservation
1B	P Office	7.88	50908	SF	0.15	7636	21	4->2
2A	A Low Density Res	16.34	114	UNITS	280	31920	89	12
2A	B Medium Density Res	31.73	200	UNITS	280	66000	156	12
2A	C N/A - Recreation/Preservation				N/A	N/A	N/A	Recreation/Preservation
2B	D Low Density Res	29.58	120	UNITS	280	33600	93	9
2B	E Low Density Res	36.44	150	UNITS	280	42000	117	14
2B	F Low Density Res	26.04	160	UNITS	280	44800	124	7/8
2B	G N/A - Recreation/Preservation				N/A	N/A	N/A	Recreation/Preservation
3	A Low Density Res	65.8	117	UNITS	280	32760	91	11
3	B Medium Density Res	17.87	90	UNITS	280	25200	70	10
3	C Medium Density Res	14.76	90	UNITS	280	25200	70	10
3	D Medium Density Res	21.73	180	UNITS	280	50400	140	9
3	E Medium Density Res	7.11	45	UNITS	280	12600	35	8
3	F Medium Density Res	13.44	45	UNITS	280	12600	35	8

**Total Wastewater Flow of Phases 1A,1B,2A,2B & 3: 757,666 GPD\***

\*modeled/actual LS pump flows may differ from design flows, these flows have been used for wetwell design



ALANN ENGINEERING GROUP, INC.  
CONSULTING ENGINEERS  
888 AIRPORT ROAD, SUITE 113  
ORMOND BEACH, FL 32174  
TEL: (386) 673-7646  
FAX: (386) 673-3927


HUNTER'S RIDGE MASTER UTILITY PLAN  
FLAGLER COUNTY, FL.  
FIGURE 6: WASTEWATER MODEL

NO.	DATE	REVISION	BY

DESIGNER	KAB	DRAWN BY	MHT
FILE	1812-1	PROJECT	1812-1
DATE	05-06-2017	SCALE	1" = 600'

SHEET  
**SEWER**

TABLE 7: SENSITIVITY ANALYSIS - Run 1 (LS 2, 6)						
Location	Design Flow (GPM)	Design Elevation (FT)	Design Head (FT)	Flow @ Pump (GPM)	Downstream Pressure @ Pump (PSI)	
LS 2	338	14	100	302.86	47.39	
<b>LS 6</b>	197	14	75	192.04	<b>35.98</b>	
Breakaway Trails	700	17	118	813.03	41.27	
Ormond Green	150	21	70	125.12	26.04	
Saddlers Run	150	20	110	211.33	29.47	
Breakaway Trails Connection on Airport Rd. Pressure =24.79 psi						



# Pump Sizing

## Project Data

Tenant	Unit Type	Units	ERU Factor	ERU's	ERU (GPD)	ADF (GPD)	ADF (GPM)
Single Family	Lot	40	1.000	40	280	11,200	7.78
Average Daily Flow						11,200 GPD	
						7.78 GPM	
Peaking Factor / Minimizing Factor				4		0.25	
Peak Flow / Minimum Flow				31.11		1.94 GPM	
Flow Used For Calcs						31 GPM	
						0.07 CFS	

Effluent Pipe Diameter	4	Inches
Area	0.087	SF
Velocity	2.0	FPS
Flow Rate Range	78	GPM
		196

Highest Elev.=	24.00	Feet
Press. @ Conn.=	35.98	PSI =
1st Pump on Elev.=	20.47	Feet
Pumps Off Elev.=	18.32	Feet
Gravity In =	21.97	Feet
High Head Static Head =	88.77	Feet



# Pump Sizing

		Prop. Station Piping		Proposed Forcemain	
Pipe Length (ft)			25		54
Pipe Size (in)			3.0		4.0
Inside Diameter (in)			3.0		4.0
Area (sf)			0.049		0.087
Roughness C		PVC	130	PVC	130
<b>Fittings:</b>	K	Number	Sub-K	Number	Sub-K
<b>Disch. Conn.</b>					
90 deg.	0.60	3	1.80	0	0.00
45 deg.	0.40	2	0.80	0	0.00
22.5 deg.	0.25	0	0.00	0	0.00
5.625 deg.	0.15	0	0.00	0	0.00
Wye	0.50	1	0.50	0	0.00
Expansion	0.20	0	0.00	0	0.00
Contraction	0.50	0	0.00	0	0.00
Gate Valve	0.40	2	0.80	1	0.40
Check Valve	2.50	1	2.50	0	0.00
			6.40		
				0.40	

5 Q increment							High Head Headloss
Q (gpm)	Velocity (ft/sec)	Pipe (ft)	Fittings (ft)	Velocity (ft/sec)	Pipe (ft)	Fittings (ft)	Total (ft)
0	0.00	0.00	0.00	0.00	0.00	0.00	88.77
5	0.23	0.00	0.01	0.13	0.00	0.00	88.78
10	0.45	0.01	0.02	0.26	0.01	0.00	88.81
15	0.68	0.02	0.05	0.38	0.01	0.00	88.86
20	0.91	0.04	0.08	0.51	0.02	0.00	88.92
25	1.14	0.06	0.13	0.64	0.03	0.00	89.00
30	1.36	0.08	0.18	0.77	0.04	0.00	89.09
35	1.59	0.11	0.25	0.89	0.06	0.00	89.20
40	1.82	0.14	0.33	1.02	0.07	0.01	89.32
45	2.04	0.17	0.42	1.15	0.09	0.01	89.47
50	2.27	0.21	0.51	1.28	0.11	0.01	89.62
55	2.50	0.25	0.62	1.40	0.14	0.01	89.80
60	2.72	0.30	0.74	1.53	0.16	0.01	89.98
65	2.95	0.35	0.87	1.66	0.18	0.02	90.19
70	3.18	0.40	1.00	1.79	0.21	0.02	90.41
75	3.41	0.45	1.15	1.92	0.24	0.02	90.64
80	3.63	0.51	1.31	2.04	0.27	0.03	90.89
85	3.86	0.57	1.48	2.17	0.30	0.03	91.15
90	4.09	0.63	1.66	2.30	0.34	0.03	91.43
95	4.31	0.70	1.85	2.43	0.37	0.04	91.73

# Wet Well Design


Wet Well Diameter= 4 ft  
 Area = 12.57 SF  
 Unit Volume = 94.0 gal/ft

## Storage Depth

Tr = Vr/(Q-S) + Vr/S, rearranging this equation, we get: Vr = (-S(S-Q)Tr)/Q		
S = Critical In-Flow =	15.56	gpm = ADF x 2
Qina = ADF to Wetwell	7.78	gpm
Pf = Peaking Factor	4.00	
Qinp = PDF to Wetwell	31.11	gpm
Q = Peak Out-Flow Rate =	80.00	gpm
Minimum Cycle Time =	10	minutes
Emergency Storage Time =	0	minutes
Tr = Cycle Time Required =	10	minutes
Vr = Volume Required =	200	gallons = (Q*Tr)/4
Dr = Storage Depth Required =	2.13	feet = Vr / (Unit Volume)
Da = Actual Storage Depth =	2.15	feet
Volume Actual (Va) =	202.1	gallons = Unit Volume x Da

## Total Actual Cycle Time

Influent Condition	ADF	PDF	
T1 = Pump Run Time =	2.8	4.1	minutes $T1 = \frac{Va}{Qout - Qin}$
T2 = Pump Off Time =	26.0	6.5	minutes $T2 = \frac{Va}{Qin}$
Tc = Total Cycle Time =	28.8	10.6	minutes $Tc = T1 + T2$



# Wet Well Buoyancy Check

Top Elevation =	26.50
Groundwater =	26.50
Sump Elevation =	16.82

Inside Diameter, d =	4	feet
Wall Thickness =	8.00	inches
Outside Diameter =	5.33	feet
Top Slab Extension =	0.00	feet
Diameter, D =	5.33	feet
Thickness, h =	0.67	feet
Bottom Slab Extension =	1.00	feet
Diameter, D =	7.33	feet
Thickness, h =	1.5	feet

\*Groundwater assumed at top elevation for calculation purposes.

## Buoyant Forces

<i>Top Slab:</i>	Force = Vol. x 62.4 lb/cf (water) =	Force
	Volume = <input type="text" value="14.9"/> CF	<input type="text" value="929.3"/> lbs.
<i>Bottom Slab:</i>	Volume = <input type="text" value="63.4"/> CF	<input type="text" value="3,953.3"/> lbs.
<i>Wet Well Cylinder:</i>	$V = [(3.14 \times d^2)/4] \times (\text{groundwater} - \text{bottom})$	
	Volume = <input type="text" value="216.2"/> CF	<input type="text" value="13,493.8"/> lbs.
<b>Total Buoyant Force =</b>		<b>18,376.4 lbs.</b>


## Down Forces

<b>Concrete Weight</b>	Weight = Volume x 150 lb/cf (reinf. Conc.)	Force
<i>Bottom Slab:</i>	Volume = <input type="text" value="63.4"/> CF	<input type="text" value="9,503.0"/> lbs.
<i>Wet Well Cylinder:</i>	Volume = <input type="text" value="94.6"/> CF	<input type="text" value="14,191.2"/> lbs.
Sub-Total		23,694.2 lbs.
<b>Soil Weight</b>	Weight = Volume x (115 lb/cf - 62.4 lb/cf)	Force
<i>Over Bottom Slab Extension</i>	Volume = <input type="text" value="192.6"/> CF	<input type="text" value="10,130.5"/> lbs.
Sub-Total		10,130.5 lbs.
<b>Total Down Force =</b>		<b>33,824.7 lbs.</b>

**Factor of Safety: 1.84**

Note that the weight of the pumps and other equipment is not included.

Curve number		<b>Pump performance curves</b>			<b>SULZER</b>	
Reference curve PIR-PE-C-60HZ						
					Discharge DN32	Frequency 60 Hz
Density 62.31 lb/ft <sup>3</sup>	Viscosity 1.077E-5 ft <sup>2</sup> /s	Test Standard ISO 9906, HI 11.6/14.6≤10kW			Rated speed 3521 rpm	Date 2022-09-06
Flow 80 US g.p.m.	Head 95 ft	Shaft power	Power input	Rated power P2 6.71 hp	Hyd. efficiency	NPSH



Installation wet well				
Impeller size 160 mm	N° of vanes 5	Impeller Macerator	Solid size	Revision

Sulzer reserves the right to change any data and dimensions without prior notice and can not be held responsible for the use of information contained in this software.

spaix® 5-2022.2 - 2022/08/09 (Build 471), 64 bit  
data version June 22.1

Frequency  
60 Hz


PE1

# Motor performance curve

## PE45/2-C-60HZ PIR PE1



Rated power 6.71 hp	Service factor 1.3	Nominal Speed 3510 rpm	Number of poles 2	Rated voltage 230 V	Date 2022-09-06
------------------------	-----------------------	---------------------------	----------------------	------------------------	--------------------



Symbol	No loac	25 %	50 %	75 %	100 %	125 %
P2/ hp	0	1.676	3.353	5.029	6.705	8.381
P1/ hp	0.584	2.142	3.839	5.612	7.526	9.6
I / A	4.2	6.38	9.06	12.26	15.98	20.2
cos	0.2603	0.6284	0.7932	0.8568	0.8816	0.8897
n / rpm	3600	3589	3566	3537	3503	3462
s / %	0	0.3066	0.9422	1.752	2.693	3.834
M / lbf ft	0	2.453	4.938	7.468	10.05	12.72
/ %	0	78.26	87.33	89.61	89.09	87.3

Tolerance according to VDE 0530 T1 12.84 for rated power

Starting current 120 A	Starting torque	Moment of inertia 0.119 lb ft <sup>2</sup>	No. starts per hour 15
---------------------------	-----------------	---	---------------------------

**SULZER**

Massblatt PIRANHA PE30/2 Nassinstallation  
 Dimension sheet WET-WELL Installation  
 Dimensioni Installazione sommersa  
 Hoja de dimensiones instalación sumergida  
 Plan d'encombrement Installation noyée



No: AN-M.04.039 -02  
 Drawn: 25/09/09 D.Whelan  
 Issue Date: 09/06/2013  
 Änderungen vorbehalten  
 Technical changes reserved  
 Con riserva di modifiche  
 Con reserva de modificaciones  
 Sous réserve de modification

**50 Hz**

Typ Type Tipo	Gewicht Weight Poids Peso (lbs)
PE 30/2	207

**60 Hz**

Typ Type Tipo	Gewicht Weight Poids Peso (lbs)
PE 25/2W	207
PE 28/2	207
PE 35/2	207
PE 35/2W	207
PE 45/2	207
PE 45/2W	207

**U.S.**

Gewicht: Beinhaltet Pumpe, Halterung (Fussstück) und Kabel (50 Hz = 10 m; 60 Hz = 15 m)  
 Weight: includes pump, slider bracket and cable (50 Hz = 10 m; 60 Hz = 15 m)  
 Peso: include pompa, pezzo intermedio a cavo (50 Hz = 10 m; 60 Hz = 15 m)  
 Peso: Incluye bomba, soporte deslizante y cable (50 Hz = 10 m; 60 Hz = 15 m)  
 Poids : incluant la pompe, le coulisseau et le câble (50 Hz = 10 m; 60 Hz = 15 m)

Guss-Allgemeintoleranzen nach DIN1680 - GTB16  
 General tolerances for castings in acc. to DIN1680-GTB16  
 Tolleranze generali delle fusioni secondo DIN1680-GTB16  
 Tolerancias generales para la fundición seg. de DIN1680-GTB16  
 Tolérance générale de la fonderie selon DIN1680-GTB16